



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779
T: 631.580.3191 • F: 631.580.3195 • W: envirohealth.org

November 5, 2025

Mr. Richard Pittore
Irvington Union Free School District
6 Dows Lane
Irvington, NY 10533

Re: **Annual Water Fountain Sampling - 2025**

Dear Mr. Pittore,

On October 29, 2025, EnviroScience Consultants, LLC performed an annual water sampling event at the Irvington Union Free School District. Samples were collected at Main Street School, Dows Lane Elementary School, and at the Middle School & High School Campus from water fountains, bottle fillers, and ice machines.

First draw samples were collected in wide-mouth 250 milliliter containers and during the early morning hours, prior to any water sources being used. The samples were transported to New York Environmental Laboratory and were analyzed for lead concentration. The current limit for lead in drinking water is 5 parts per billion (ppb). There were no exceedances.

Please see the attached lab reports for detailed results at each location.

Should you have any questions, please feel free to contact me.

Sincerely,

A handwritten signature in dark ink, appearing to read "Susan Richter".

Susan Richter
Environmental Project Manager

Laboratory Report

NYE Report #: 2406389-31472

October 22, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Irvington UFSD; Main Street School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on October 18, 2024. New York Environmental analyzed the samples on October 21, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	17 Oct 2024
Date Received:	18 Oct 2024
Date Analyzed:	21 Oct 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
241018P019	1	3rd Floor-BF, Initial	0.001	<0.001	mg/L	
241018P020	2	3rd Floor-WF, Initial	0.001	<0.001	mg/L	
241018P021	3	2nd Floor-BF, Initial	0.001	<0.001	mg/L	
241018P022	4	2nd Floor-WF, Initial	0.001	<0.001	mg/L	
241018P023	5	Teachers Lounge (206)-IM, Initial	0.001	<0.001	mg/L	
241018P024	6	1st Floor-BF, Initial	0.001	<0.001	mg/L	
241018P025	7	1st Floor-WF, Initial	0.001	<0.001	mg/L	
241018P026	8	Gym-BF, Initial	0.001	<0.001	mg/L	
241018P027	9	Gym-WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

81714

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION
SAMPLE COLLECTION FORM

241018 P019-P027

Page 1 of 1

CLIENT INFORMATION

Name: Enviroscience Consultants, LLC

Address:

2150 Smithtown Avenue, Suite 3, Ronkonkoma, NY 11779

Client Rep: John Driscoll

W.O. No.

CONSULTANT INFORMATION

Name: Enviroscience Consultants, LLC

Address: 2150 Smithtown Avenue, Suite 3, Ronkonkoma, NY 11779

Project Manager:

Field Tech: Pamela Chadderton

Project No: 24298

PROJECT INFORMATION

DISTRICT NAME:

Irvington UFSD

SCHOOL NAME:

Main Street School

DATE OF SAMPLING:

10/17/2024

SAMPLE DATA

Sample Description/ID (ID must match container label)		OUTLET INFORMATION	CONTAINER INFORMATION		SAMPLE TYPE			Time of Collection	Lead Concentration (ppb)
Sample #	Sample Outlet Location / Coordinates	Fixture Type (Enter Code)	Size	Preservatives	Initial	Follow-up	Length of Flush		
1	3 rd Floor	BF	250 ml	HNO ₃	✓			7:05	
2	"	WF	250 ml	HNO ₃	✓			7:05	
3	2 nd Floor	BF	250 ml	HNO ₃	✓			7:10	
4	"	WF	250 ml	HNO ₃	✓			7:10	
5	Teachers Lounge (206)	IM	250 ml	HNO ₃	✓			7:12	
6	1 st Floor	BF	250 ml	HNO ₃	✓			7:12	
7	"	WF	250 ml	HNO ₃	✓			7:13	
8	Gym	BF	250 ml	HNO ₃	✓			7:15	
9	"	WF	250 ml	HNO ₃	✓			7:15	
			250 ml	HNO ₃					

CHAIN OF CUSTODY

Relinquished by:	Received by:	Date:	Time:
I. Pamela Chadderton	MARCEL	10/18/24	1230
II.			
III.			

LABORATORY INFORMATION


Lab Name: NEW YORK ENVIRONMENTAL AND ANALYTICAL LABS., INC.	Date:	Time:	Method of Analysis:
Analyzed by: Alvin Lee	10/21/24	1:00 PM	200.9
Q.C. by:			
Method of shipment/delivery: ☐ US Mail ☐ UPS ☐ Fed-Ex ☐ Courier ☒ Hand Delivery ☐ Other:			

INSTRUCTIONS TO THE LABORATORY

TURNAROUND TIME:	☐ Analyze follow-up sample(s) ONLY when initial sample exceeds 5 ppb	REPORT RESULTS ASAP TO:	
☐ RUSH ☐ 24 hour ☐ 48 hour	☐ Analyze both initial and follow up samples	☐ Phone	☐ Fax:
☐ OTHER:	☐ Other:	☐ Email:	☐ Mail report to above address

Validated 10/18/24 1:00 PM - AL
Lot: 1123090

2406389



Laboratory Report

NYE Report #: 2406390-31473

October 22, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Irvington UFSD; Dows Lane Elementary School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on October 18, 2024. New York Environmental analyzed the samples on October 21, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	17 Oct 2024
Date Received:	18 Oct 2024
Date Analyzed:	21 Oct 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
241018P028	1	Gym-BF, Initial	0.001	<0.001	mg/L	
241018P029	2	Gym-WF, Initial	0.001	<0.001	mg/L	
241018P030	3	112 (PLTW)-WF, Initial	0.001	0.004	mg/L	
241018P031	4	115 (PLTW)-WF, Initial	0.001	0.005	mg/L	
241018P032	5	Multi-Purpose Room-WF, Initial	0.001	<0.001	mg/L	
241018P033	6	2nd Floor Lobby-BF, Initial	0.001	<0.001	mg/L	
241018P034	7	2nd Floor Lobby-WF, Initial	0.001	<0.001	mg/L	
241018P035	8	2nd Floor Hallway-WF, Initial	0.001	0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

81715

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION
SAMPLE COLLECTION FORM

241018P028-P035

Page 1 of 1

CLIENT INFORMATION

Name: Enviroscience Consultants, LLC

Address:

2150 Smithtown Avenue, Suite 3, Ronkonkoma, NY 11779

Client Rep: John Driscoll

W.O. No.

CONSULTANT INFORMATION

Name: Enviroscience Consultants, LLC

Address: 2150 Smithtown Avenue, Suite 3, Ronkonkoma, NY 11779

Project Manager:

Field Tech:

Pamela Chadderton

Project No.:

24298

PROJECT INFORMATION

DISTRICT NAME:

Irvington UFSD

SCHOOL NAME:

Dows Lane Elementary School

DATE OF SAMPLING:

10/17/24

SAMPLE DATA

Sample Description/ID
(ID must match container label)

"Green" DL

Sample #	Sample Outlet Location / Coordinates	OUTLET INFORMATION Fixture Type (Enter Code)	CONTAINER INFORMATION		SAMPLE TYPE			Time of Collection	Lead Concentration (ppb)
			Size	Preservatives	Initial	Follow-up	Length of Flush		
1	Gym	BF	250 ml	HNO ₃	✓			6:37	
2	"	WF	250 ml	HNO ₃	✓			6:38	
3	112 (PLTW)	WF	250 ml	HNO ₃	✓			6:40	
4	115 (PLTW)	WF	250 ml	HNO ₃	✓			6:41	
5	Multi-Purpose Room	WF	250 ml	HNO ₃	✓			6:44	
6	2nd Floor Lobby	BF	250 ml	HNO ₃	✓			6:46	
7	" "	WF	250 ml	HNO ₃	✓			6:47	
8	2nd Floor Hallway	WF	250 ml	HNO ₃	✓			6:50	
			250 ml	HNO ₃					
			250 ml	HNO ₃					

CHAIN OF CUSTODY

Relinquished by:

Received by:

Date:

Time:

I. Pamela Chadderton

M. Kent

10/18/24

1230

II.

III.

LABORATORY INFORMATION

Lab Name: NEW YORK ENVIRONMENTAL AND
ANALYTICAL LABS., INC.

Date:

Time:

Method of
Analysis:

Analyzed by: Alvin Lee

10/21/24

1:00 PM

200.9

Q.C. by:

Method of shipment/delivery:

☐ US Mail☐ UPS☐ Fed-Ex☐ Courier☒ Hand Delivery☐ Other:

INSTRUCTIONS TO THE LABORATORY

TURNAROUND TIME:

☐ RUSH ☐ 24 hour ☐ 48 hour☐ OTHER:☐ Analyze follow-up sample(s) **ONLY** when initial sample exceeds 5 pbb☐ Analyze both initial and follow up samples☐ Other:

REPORT RESULTS ASAP TO:

☐ Phone☐ Fax:☐ Email:☐ Mail report to above addressacidified 10/18/24 1:00 PM - AL
101123090

2406390



Laboratory Report

NYE Report #: 2406391-31474

October 22, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Irvington UFSD; Irvington Middle & High School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on October 18, 2024. New York Environmental analyzed the samples on October 21, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	17 Oct 2024
Date Received:	18 Oct 2024
Date Analyzed:	21 Oct 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
241018P036	1	LGA-Library Hallway-BF, Initial	0.001	<0.001	mg/L	
241018P037	2	LGA-Library Hallway-WF, Initial	0.001	<0.001	mg/L	
241018P038	3	Middle School-A Wing-BF, Initial	0.001	<0.001	mg/L	
241018P039	4	Middle School-A Wing-WF, Initial	0.001	<0.001	mg/L	
241018P040	5	Middle School-B Wing-BF, Initial	0.001	<0.001	mg/L	
241018P041	6	Middle School-B Wing-WF, Initial	0.001	<0.001	mg/L	
241018P042	7	Middle School-C Wing-BF, Initial	0.001	<0.001	mg/L	
241018P043	8	Middle School-C Wing-WF, Initial	0.001	<0.001	mg/L	
241018P044	9	Middle School-D Wing-BF, Initial	0.001	<0.001	mg/L	
241018P045	10	Middle School-D Wing-WF, Initial	0.001	<0.001	mg/L	
241018P046	11	Theater/Gym-Outside Boys Locker Room-WF, Initial	0.001	<0.001	mg/L	
241018P047	12	Theater/Gym-1st Floor Lobby-BF, Initial	0.001	<0.001	mg/L	
241018P048	13	Theater/Gym-1st Floor Lobby-WF, Initial	0.001	<0.001	mg/L	
241018P049	14	Theater/Gym-2nd Floor Lobby-WF, Initial	0.001	<0.001	mg/L	
241018P050	15	CLP-Outdoor-BF, Initial	0.001	<0.001	mg/L	
241018P051	16	CLP-Outdoor-WF, Initial	0.001	<0.001	mg/L	
241018P052	17	CLP-Outdoor by Inclusive Restroom-BF, Initial	0.001	<0.001	mg/L	
241018P053	18	CLP-Outdoor by Inclusive Restroom-WF, Initial	0.001	<0.001	mg/L	
241018P054	19	High School-Garden Level-BF, Initial	0.001	<0.001	mg/L	
241018P055	20	High School-Garden Level-WF, Initial	0.001	<0.001	mg/L	
241018P056	21	High School-2nd Floor Hallway-BF, Initial	0.001	<0.001	mg/L	
241018P057	22	High School-2nd Floor by H200-WF, Initial	0.001	<0.001	mg/L	
241018P058	23	High School-2nd Floor by H200-WF, Initial	0.001	<0.001	mg/L	
241018P059	24	High School-Cafeteria-BF, Initial	0.001	<0.001	mg/L	
241018P060	25	High School-Cafeteria-WF, Initial	0.001	<0.001	mg/L	
241018P061	26	CMS-2nd Floor Hallway by S206-WF, Initial	0.001	<0.001	mg/L	



Date Collected:	17 Oct 2024
Date Received:	18 Oct 2024
Date Analyzed:	21 Oct 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
241018P062	27	CMS-1st Floor Hallway (East End)-BF, Initial	0.001	<0.001	mg/L	
241018P063	28	CMS-1st Floor Hallway (East End)-WF, Initial	0.001	<0.001	mg/L	
241018P064	29	High School-Outside Main Office-BF, Initial	0.001	<0.001	mg/L	
241018P065	30	High School-Outside Main Office-WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

81716

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION
SAMPLE COLLECTION FORM

Page 1 of 3

CLIENT INFORMATION

Name: Enviroscience Consultants, LLC

Address:

2150 Smithtown Avenue, Suite 3, Ronkonkoma, NY 11779

Client Rep: John Driscoll

W.O. No.

CONSULTANT INFORMATION

Name: Enviroscience Consultants, LLC

Address: 2150 Smithtown Avenue, Suite 3, Ronkonkoma, NY 11779

Project Manager:

Field Tech:

Pamela Chadder ton

Project No.:

24298

PROJECT INFORMATION

DISTRICT NAME:

Irvington UFSD

SCHOOL NAME:

Irvington Middle & High School

DATE OF SAMPLING:

10/17/24

SAMPLE DATA

Sample Description/ID
(ID must match container label)

"Black" MH

Sample #	Sample Outlet Location / Coordinates	OUTLET INFORMATION Fixture Type (Enter Code)	CONTAINER INFORMATION		SAMPLE TYPE			Time of Collection	Lead Concentration (ppb)
			Size	Preservatives	Initial	Follow-up	Length of Flush		
1	LGA- Library Hallway	BF	250 ml	HNO ₃	✓			5:35	
2	" " "	WF	250 ml	HNO ₃	✓			5:35	
3	Middle School- A Wing	BF	250 ml	HNO ₃	✓			5:40	
4	" " "	WF	250 ml	HNO ₃	✓			5:40	
5	" " - B Wing	BF	250 ml	HNO ₃	✓			5:42	
6	" " "	WF	250 ml	HNO ₃	✓			5:42	
7	" " - C Wing	BF	250 ml	HNO ₃	✓			5:44	
8	" " "	WF	250 ml	HNO ₃	✓			5:44	
9	" " - D Wing	BF	250 ml	HNO ₃	✓			5:46	
10	" " "	WF	250 ml	HNO ₃	✓			5:46	

CHAIN OF CUSTODY

Relinquished by:	Received by:	Date:	Time:
I. Pamela Chadder ton	M. Reed	10/18/24	1230
II.			
III.			

LABORATORY INFORMATION

Lab Name: NEW YORK ENVIRONMENTAL AND ANALYTICAL LABS., INC.	Date:	Time:	Method of Analysis:
Analyzed by: Alvin Lee (22)	10/21/24	11:00 AM	200.9
Q.C. by:			
Method of shipment/delivery: ☐ US Mail ☒ UPS ☐ Fed-Ex ☐ Courier			
☒ Hand Delivery ☐ Other:			

INSTRUCTIONS TO THE LABORATORY

TURNAROUND TIME:	☐ Analyze follow-up sample(s) ONLY when initial sample exceeds 5 pbb	REPORT RESULTS ASAP TO:
☐ RUSH ☐ 24 hour ☐ 48 hour	☐ Analyze both initial and follow up samples	☐ Phone
☐ OTHER:	☐ Other:	☐ Fax:
		☐ Email:
		☐ Mail report to above address

acidified 10/18/24 1100 PM -AL
lot: 1123090

2406391



POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Page 2 of 3

CLIENT INFORMATION

Name: Enviroscience Consultants, LLC	
Address: 2150 Smithtown Avenue, Suite 3, Ronkonkoma, NY 11779	
Client Rep: John Driscoll	W.O. No.

CONSULTANT INFORMATION

Name: Enviroscience Consultants, LLC	
Address: 2150 Smithtown Avenue, Suite 3, Ronkonkoma, NY 11779	
Project Manager:	
Field Tech: Pamela Chodderton	Project No.: 24298

PROJECT INFORMATION

DISTRICT NAME: Irvington UFSD	SCHOOL NAME: Irvington Middle & High School	DATE OF SAMPLING: 10/17/24
---	---	--------------------------------------

SAMPLE DATA

Sample Description/ID (ID must match container label)		OUTLET INFORMATION	CONTAINER INFORMATION		SAMPLE TYPE			Time of Collection	Lead Concentration (ppb)
Sample #	Sample Outlet Location / Coordinates	Fixture Type (Enter Code)	Size	Preservatives	Initial	Follow-up	Length of Flush		
11	Theater / Gym - Outside Boys Locker Room	WF	250 ml	HNO ₃	✓			5:48	
12	Theater / Gym - 1 st Floor Lobby	BF	250 ml	HNO ₃	✓			5:49	
13	" " " "	WF	250 ml	HNO ₃	✓			5:49	
14	" " - 2 nd Floor Lobby	WF	250 ml	HNO ₃	✓			5:50	
15	CLP - Outdoor	BF	250 ml	HNO ₃	✓			5:55	
16	CLP - Outdoor	WF	250 ml	HNO ₃	✓			5:55	
17	CLP - Outdoor by Inclusive Restroom	BF	250 ml	HNO ₃	✓			6:00	
18	" " " "	WF	250 ml	HNO ₃	✓			6:00	
19	High School - Garden Level	BF	250 ml	HNO ₃	✓			6:05	
20	" "	WF	250 ml	HNO ₃	✓			6:05	

CHAIN OF CUSTODY

Relinquished by:	Received by:	Date:	Time:
I. Pamela Chodderton	Marked	10/18/24	1230
II.			
III.			

LABORATORY INFORMATION

Lab Name: NEW YORK ENVIRONMENTAL AND ANALYTICAL LABS., INC	Date:	Time:	Method of Analysis:
Analyzed by: [Signature]	10/21/24	11:00 AM	200.9
Q.C. by:			
Method of shipment/delivery: ☐ US Mail ☐ UPS ☐ Fed-Ex ☐ Courier ☐ Hand Delivery ☐ Other:			

INSTRUCTIONS TO THE LABORATORY

TURNAROUND TIME:	☐ Analyze follow-up sample(s) ONLY when initial sample exceeds 5 pbb	REPORT RESULTS ASAP TO:
☐ RUSH ☐ 24 hour ☐ 48 hour	☐ Analyze both initial and follow up samples	☐ Phone
☐ OTHER:	☐ Other:	☐ Fax:
		☐ Mail report to above address

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Page 3 of 3

CLIENT INFORMATION

Name: Enviroscience Consultants, LLC	
Address: 2150 Smithtown Avenue, Suite 3, Ronkonkoma, NY 11779	
Client Rep: John Driscoll	W.O. No.

CONSULTANT INFORMATION

Name: Enviroscience Consultants, LLC	
Address: 2150 Smithtown Avenue, Suite 3, Ronkonkoma, NY 11779	
Project Manager:	
Field Tech: Pamela Chadderton	Project No.: 24298

PROJECT INFORMATION

DISTRICT NAME: Irvington UFSD	SCHOOL NAME: Irvington Middle & High School	DATE OF SAMPLING: 10/17/24
---	---	--------------------------------------

SAMPLE DATA

Sample Description/ID (ID must match container label)		OUTLET INFORMATION	CONTAINER INFORMATION		SAMPLE TYPE			Time of Collection	Lead Concentration (ppb)
Sample #	Sample Outlet Location / Coordinates	Fixture Type (Enter Code)	Size	Preservatives	Initial	Follow-up	Length of Flush		
21	High School - 2 nd Floor Hallway	BF	250 ml	HNO ₃	✓			6:07	
22	↓ by H200	WF	250 ml	HNO ₃	✓			6:09	
23	↓ " "	WF	250 ml	HNO ₃	✓			6:09	
24	High School - Cafeteria	BF	250 ml	HNO ₃	✓			6:12	
25	" "	WF	250 ml	HNO ₃	✓			6:12	
26	CMS - 2 nd Floor Hallway by S206	WF	250 ml	HNO ₃	✓			6:17	
27	CMS - 1 st Floor Hallway (East End)	BF	250 ml	HNO ₃	✓			6:19	
28	" " "	WF	250 ml	HNO ₃	✓			6:19	
29	High School - Outside Main Office	BF	250 ml	HNO ₃	✓			6:25	
30	" " "	WF	250 ml	HNO ₃	✓			6:25	

CHAIN OF CUSTODY

Relinquished by:	Received by:	Date:	Time:
I. Pamela Chadderton	M. M. M.	10/18/24	1230
II.			
III.			

LABORATORY INFORMATION

Lab Name: NEW YORK ENVIRONMENTAL AND ANALYTICAL LABS., INC	Date:	Time:	Method of Analysis:
Analyzed by: [Signature]	10/21/24	11:00 AM	200.9
Q.C. by:			
Method of shipment/delivery: ☐ US Mail ☐ UPS ☐ Fed-Ex ☐ Courier ☐ Hand Delivery ☐ Other:			

INSTRUCTIONS TO THE LABORATORY

TURNAROUND TIME:	☐ Analyze follow-up sample(s) ONLY when initial sample exceeds 5 ppb	REPORT RESULTS ASAP TO:
☐ RUSH ☐ 24 hour ☐ 48 hour	☐ Analyze both initial and follow up samples	☐ Phone
☐ OTHER:	☐ Other:	☐ Fax:
		☐ Mail report to above address