



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779
T: 631.580.3191 • F: 631.580.3195 • W: envirohealth.org

May 10, 2024

Mr. Richard Pittore
Irvington Union Free School District
6 Dows Lane
Irvington, NY 10533

Re: **Districtwide Lead in Drinking Water Sampling 2023-2025**

Dear Mr. Pittore,

On May 8, 2024, EnviroScience Consultants, LLC performed a semi-annual water sampling event at the Irvington Union Free School District. Samples were collected at Main Street School, Dows Lane Elementary School, and at the Middle School & High School Campus from water fountains, bottle fillers, and other sources selected by the district.

First draw samples were collected in wide-mouth 250 milliliter containers and during the early morning, prior to any water sources being used. The samples were transported to New York Environmental Laboratory and were analyzed for lead concentration. The current limit for lead in drinking water is 5 parts per billion (ppb). Any locations that were above the limit were signed or taken out of service pending remediation.

The following locations were above the limit:

- Dows Lane Elementary School:
- Room 102 - WF

There were no other exceedances.

Please see the attached Outlet Inventory tables and lab reports for detailed results at each location.

Should you have any questions, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads "Shannon Gallagher".

Shannon Gallagher
Environmental Inspector

Laboratory Report

NYE Report #: 2402961-29585

May 9, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Irvington UFSD; Main Street School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 08, 2024. New York Environmental analyzed the samples on May 09, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	08 May 2024
Date Received:	08 May 2024
Date Analyzed:	09 May 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240508N025	1	1st Floor-WF, Initial	0.001	<0.001	mg/L	
240508N026	2	1st Floor-BF, Initial	0.001	<0.001	mg/L	
240508N027	3	2nd Floor-WF, Initial	0.001	<0.001	mg/L	
240508N028	4	2nd Floor-BF, Initial	0.001	<0.001	mg/L	
240508N029	5	Teachers Lounge (206)-IM, Initial	0.001	<0.001	mg/L	
240508N030	6	Nurse's Office-SK, Initial	0.001	<0.001	mg/L	
240508N031	7	3rd Floor-WF, Initial	0.001	<0.001	mg/L	
240508N032	8	3rd Floor-BF, Initial	0.001	<0.001	mg/L	
240508N033	9	Gym-WF, Initial	0.001	<0.001	mg/L	
240508N034	10	Gym-BF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
3rd Floor	WF	App	<1.0	5/8/2024	-	-	-	-
3rd Floor	BF	App	<1.0	5/8/2024	-	-	-	-
2nd Floor	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
2nd Floor	BF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
Teachers Lounge (206)	IM	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
Nurse's Office	SK	App	<1.0	5/8/2024	-	-	-	-
1st Floor	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
1st Floor	BF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
Gym	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
Gym	BF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-

Laboratory Report

NYE Report #: 2402962-29586

May 9, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Irvington UFSD; Dows Lane Elementary School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 08, 2024. New York Environmental analyzed the samples on May 09, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	08 May 2024
Date Received:	08 May 2024
Date Analyzed:	09 May 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240508N035	D1	Gym-WF, Initial	0.001	<0.001	mg/L	
240508N036	D2	Gym-BF, Initial	0.001	<0.001	mg/L	
240508N037	D3	Room 101-WF, Initial	0.001	0.002	mg/L	
240508N038	D4	Room 102-WF, Initial	0.001	0.006	mg/L	H
240508N039	D5	Room 103-WF, Initial	0.001	0.001	mg/L	
240508N040	D6	Room 104-WF, Initial	0.001	0.002	mg/L	
240508N041	D7	Room 105-WF, Initial	0.001	0.003	mg/L	
240508N042	D8	Room 106-WF, Initial	0.001	0.002	mg/L	
240508N043	D9	Room 107-WF, Initial	0.001	0.001	mg/L	
240508N044	D10	Nurse's Office 108-SK, Initial	0.001	0.005	mg/L	
240508N045	D11	Room 109-WF, Initial	0.001	0.002	mg/L	
240508N046	D12	Room 112 (PLTW)-WF, Initial	0.001	0.002	mg/L	
240508N047	D13	Room 111-WF, Initial	0.001	0.002	mg/L	
240508N048	D14	Room 115 (PLTW)-WF, Initial	0.001	0.004	mg/L	
240508N049	D15	Room 127-WF, Initial	0.001	0.003	mg/L	
240508N050	D16	Room 129-WF, Initial	0.001	0.001	mg/L	
240508N051	D17	Multi-Purpose Room-WF, Initial	0.001	<0.001	mg/L	
240508N052	D18	2nd Floor Lobby-WF, Initial	0.001	<0.001	mg/L	
240508N053	D19	2nd Floor Lobby-BF, Initial	0.001	<0.001	mg/L	
240508N054	D20	Room 205-WF, Initial	0.001	0.002	mg/L	
240508N055	D21	2nd Floor Hallway-WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



Irvington UFSD
Dows Lane Elementary School

School Water Outlet Inventory

Lead in School Drinking Water - October 2023

Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
Gym	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
Gym	BF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
Room 101	WF	App	2.0	5/8/2024	-	-	-	-
			2.0	10/27/2023	-	-	-	-
Room 102	WF	App	6.0	5/8/2024				Removed from Service; Pending Remediation
			3.0	10/27/2023	-	-	-	-
Room 103	WF	App	1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
Room 104	WF	App	2.0	5/8/2024	-	-	-	-
			1.0	10/27/2023	-	-	-	-
Room 105	WF	App	3.0	5/8/2024	-	-	-	-
			3.0	10/27/2023	-	-	-	-
Room 106	WF	App	2.0	5/8/2024	-	-	-	-
			2.0	10/27/2023	-	-	-	-
Room 107	WF	App	1.0	5/8/2024	-	-	-	-
			2.0	10/27/2023	-	-	-	-

Irvington UFSD
Dows Lane Elementary School

School Water Outlet Inventory

Lead in School Drinking Water - October 2023

Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
Nurse's Office 108	SK	App	5.0	5/8/2024	-	-	-	-
			5.0	10/27/2023	-	-	-	-
Room 109	WF	App	2.0	5/8/2024	-	-	-	-
			1.0	10/27/2023	-	-	-	-
Room 111	WF	App	2.0	5/8/2024	-	-	-	-
			1.0	10/27/2023	-	-	-	-
Room 112 (PLTW)	WF	App	2.0	5/8/2024	-	-	-	-
			2.0	10/27/2023	-	-	-	-
Room 115 (PLTW)	WF	App	4.0	5/8/2024	-	-	-	-
			3.0	10/27/2023	-	-	-	-
Room 126	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
Room 127	WF	App	3.0	5/8/2024	-	-	-	-
			4.0	10/27/2023	-	-	-	-
Room 128	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
Room 129	WF	App	1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-

Irvington UFSD
Dows Lane Elementary School

School Water Outlet Inventory

Lead in School Drinking Water - October 2023

Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
Room 130	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
Multi-Purpose Room	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
2nd Floor Lobby	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
2nd Floor Lobby	BF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
Room 201	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
Room 202	WF	App		10/27/2023	-	-	-	Removed from Service; No Fixture Observed
Room 203	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
Room 204	WF	App		10/27/2023	-	-	-	Removed from Service; No Fixture Observed
Room 205	WF	App	2.0	5/8/2024	-	-	-	-
			1.0	10/27/2023	-	-	-	-
Room 206	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required

Irvington UFSD
Dows Lane Elementary School

School Water Outlet Inventory

Lead in School Drinking Water - October 2023

Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
Room 207	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
Room 208	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
Room 209	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
Room 210	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
Room 211	WF	App		10/27/2023	-	-	-	Removed from Service; No Fixture Observed
2nd Floor Hallway	WF	App	<1.0	5/8/2024	-	-	-	-
			1.0	10/27/2023	-	-	-	-

Laboratory Report

NYE Report #: 2402963-29587

May 9, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Irvington UFSD; Middle School And High School Campus

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 08, 2024. New York Environmental analyzed the samples on May 09, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	08 May 2024
Date Received:	08 May 2024
Date Analyzed:	09 May 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240508N056	1	High School - Cafeteria-WF, Initial	0.001	<0.001	mg/L	
240508N057	2	High School - Cafeteria-BF, Initial	0.001	<0.001	mg/L	
240508N058	3	CMS - 2nd Floor Hallway (East End)-WF, Initial	0.001	<0.001	mg/L	
240508N059	4	CMS - 1st Floor Hallway (East End)-WF, Initial	0.001	<0.001	mg/L	
240508N060	5	CMS - 1st Floor Hallway (East End)-BF, Initial	0.001	<0.001	mg/L	
240508N061	6	High School - Outside Main Office-WF, Initial	0.001	<0.001	mg/L	
240508N062	7	High School - Outside Main Office-BF, Initial	0.001	<0.001	mg/L	
240508N063	8	High School - 2nd Floor Hallway-WF, Initial	0.001	<0.001	mg/L	
240508N064	9	High School - 2nd Floor Hallway-BF, Initial	0.001	<0.001	mg/L	
240508N065	10	CMS - 1st Floor Hallway (West End)-WF, Initial	0.001	<0.001	mg/L	
240508N066	11	LGA - Library Hallway-WF, Initial	0.001	<0.001	mg/L	
240508N067	12	LGA - Library Hallway-BF, Initial	0.001	<0.001	mg/L	
240508N068	13	Middle School - A Wing-WF, Initial	0.001	<0.001	mg/L	
240508N069	14	Middle School - A Wing-BF, Initial	0.001	<0.001	mg/L	
240508N070	15	Middle School - B Wing-WF, Initial	0.001	<0.001	mg/L	
240508N071	16	Middle School - B Wing-BF, Initial	0.001	<0.001	mg/L	
240508N072	17	Middle School - C Wing-WF, Initial	0.001	<0.001	mg/L	
240508N073	18	Middle School - C Wing-BF, Initial	0.001	<0.001	mg/L	
240508N074	19	Middle School - D Wing-WF, Initial	0.001	<0.001	mg/L	
240508N075	20	Middle School - D Wing-BF, Initial	0.001	<0.001	mg/L	
240508N076	21	Theater/Gym - Outside Boys Locker Room-WF, Initial	0.001	<0.001	mg/L	
240508N077	22	Theater/Gym - 1st Floor Lobby-WF, Initial	0.001	<0.001	mg/L	
240508N078	23	Theater/Gym - 1st Floor Lobby-BF, Initial	0.001	<0.001	mg/L	
240508N079	24	Theater/Gym - 2nd Floor Lobby-WF, Initial	0.001	<0.001	mg/L	
240508N080	25	CLP - Outdoor by Football Field-WF, Initial	0.001	<0.001	mg/L	
240508N081	26	CLP - Outdoor by Football Field-BF, Initial	0.001	<0.001	mg/L	



Date Collected:	08 May 2024
Date Received:	08 May 2024
Date Analyzed:	09 May 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
240508N082	27	CLP - Outdoor South-WF, Initial	0.001	<0.001	mg/L	
240508N083	28	CLP - Outdoor South-BF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Irvington UFSD
Middle School and High School Campus

School Water Outlet Inventory

Lead in School Drinking Water - October 2023

Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
Middle School - A Wing	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
Middle School - A Wing	BF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
Middle School - B Wing	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
Middle School - B Wing	BF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
Middle School - C Wing	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
Middle School - C Wing	BF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
Middle School - D Wing	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
Middle School - D Wing	BF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
Theater/Gym - 1st Floor Lobby	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
Theater/Gym - 1st Floor Lobby	BF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
Theater/Gym - 2nd Floor Lobby	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-

Action Level = 5.0 parts per billion (ppb) (µg/L)

Irvington UFSD
Middle School and High School Campus

School Water Outlet Inventory

Lead in School Drinking Water - October 2023

Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
Theater/Gym - Gym-left lower	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
Theater/Gym - Gym-left upper	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
Theater/Gym - Gym-right lower	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
Theater/Gym - Gym-right upper	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
Theater/Gym - Outside Boys Locker Room	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
LGA - Library Hallway	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
LGA - Library Hallway	BF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
LGA - Library Hallway	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
LGA - Gym-left	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
LGA - Gym-right	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
LGA - Gym	WF	App		10/27/2023	-	-	-	Removed from Service; No Fixture Observed
LGA - Gym	WF	App		10/27/2023	-	-	-	Removed from Service; No Fixture Observed

Irvington UFSD
Middle School and High School Campus

School Water Outlet Inventory

Lead in School Drinking Water - October 2023

Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
CLP - Outdoor by Football Field	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
CLP - Outdoor by Football Field	BF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
CLP - Outdoor South	WF	App	<1.0	5/8/2024	-	-	-	-
CLP - Outdoor South	BF	App	<1.0	5/8/2024	-	-	-	-
High School - Garden Level by Room H024	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
			<1.0	10/27/2023	-	-	-	-
High School - Garden Level by Room H024	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
			<1.0	10/27/2023	-	-	-	-
High School - Cafeteria	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
High School - Cafeteria	BF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
High School - Cafeteria	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
High School - Outside Main Office	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
High School - Outside Main Office	BF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
High School - 1st Floor Hallway	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required

Action Level = 5.0 parts per billion (ppb) (µg/L)

Irvington UFSD
Middle School and High School Campus

School Water Outlet Inventory

Lead in School Drinking Water - October 2023

Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
High School - 2nd Floor Hallway	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
			<1.0	10/27/2023	-	-	-	-
High School - 2nd Floor Hallway	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
High School - 2nd Floor Hallway	BF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
CMS - 3rd Floor Hallway (West End)	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
CMS - 2nd Floor Lobby	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required
CMS - 2nd Floor Hallway (East End)	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
CMS - 2nd Floor Hallway (West End)	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
			<1.0	10/27/2023	-	-	-	-
CMS - 1st Floor Hallway (East End)	WF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
CMS - 1st Floor Hallway (East End)	BF	App	<1.0	5/8/2024	-	-	-	-
			<1.0	10/27/2023	-	-	-	-
CMS - 1st Floor Hallway (West End)	WF	App	<1.0	5/8/2024	-	-	-	-
				10/27/2023	-	-	-	Non-functional; Sampling Required
CMS - 1st Floor Lobby	WF	App		5/8/2024	-	-	-	Non-functional; Sampling Required
				10/27/2023	-	-	-	Non-functional; Sampling Required

Action Level = 5.0 parts per billion (ppb) (µg/L)